

Integrating Wind Power into the Electric Power System



Ed DeMeo

Technical Advisor: Utility Wind Integration Group
Co-Chair, 20% Wind Energy Advisory Group
Renewable Energy Consulting Services, Inc.

NARUC Electric Reliability and Electricity Staff Subcommittees
July 20, 2008 *Portland, Oregon*



Key Integration Issues



- ❖ Market competitiveness
- ❖ Variability and Uncertainty impacts
- ❖ Mitigation of impacts
- ❖ Storage: is it needed?
- ❖ Energy, Capacity and Carbon Emissions

Natural Gas Situation (old news today)


“Today’s tight natural gas markets have been a long time in coming, and distant futures prices suggest that we are not apt to return to earlier periods of relative abundance and low prices anytime soon.”

– Alan Greenspan, Federal Reserve Chairman,
Testimony at Senate hearing, July 10, 2003

Wellhead gas costs - 2002-2003: \$3 - \$5/MMBTU


Current prices and projections exceed \$10/MMBTU

**NYMEX Natural Gas Futures Near-Month Contract Settlement
Price, West Texas Intermediate Crude Oil Spot Price, and
Henry Hub Natural Gas Spot Price**



Note: The West Texas Intermediate (WTI) crude oil price, in dollars per barrel, is converted to \$/MMBtu using a conversion factor of 5.80 MMBtu per barrel. The dates marked by vertical lines are the NYMEX near-month contract settlement dates. Source: Natural gas prices, *NGI's Daily Gas Price Index* (<http://Intelligencepress.com>); WTI price, Reuters News Service (<http://www.reuters.com>).

Source: EIA Natural Gas Weekly Update, 7-10-08



Cost Comparison



- ❖ Wind total capital cost: about \$2,200 kW today
- ❖ **Wind energy** cost: about **8¢/kWh** (without PTC)
- ❖ Includes 0.5 to 1.0¢/kWh for O&M
- ❖ Wind energy costs are **stable** over plant lifetime


Natural-gas plant fuel cost (HR 8,000 - 10,000)

\$/MMBTU:	4	6	8	10	12	gas cost
¢/kWh:	3.2 - 4	4.8 - 6	6.4 - 8	8 - 10	9.6 - 12	fuel only

- ❖ **Wind-gas synergy**: save gas when wind blows; burn gas to maintain system reliability during low winds




Time scales for grid operations



2006 Minnesota Wind Integration Study

Integration of 20% Wind Energy Can Be Managed



Total integration costs, including load-following and regulation



System Operating Costs Impacts: Results from Recent Studies (\$/MWh)

Study	Penetra- tion (%)	Regula- tion	Load- Follow	Unit- Commit	Total Impact
UWIG/Xcel	3.5	0	0.41	1.44	1.85
Pacificorp	20	0	1.6	3.0	4.6
BPA/Hirst	7	0.19	0.28	1.40	1.87
We Energies	29	1.02	0.15	1.75	2.92
Xcel/PSCO	15	0.20	0	4.77	4.97
Xcel/MNDOC	15	0.23	0	4.37	4.60
MN/MNDOC	20	0.11	0	2.00	2.11
MN/MNDOC	34	0.23	0	4.18	4.41



System Operating Costs Impacts: Minnesota DOC Studies (\$/MWh)


Study	Penetration (%)	Total Impact
Xcel/MNDOC (2004)	15	4.60
MN/MNDOC (2006)	20	2.11
MN/MNDOC (2006)	34	4.41

Why are the 2006 study impacts lower?

2004: Balancing area -- Xcel NSP MN

2006: Balancing area -- entire state of MN (4 BAs)

Also access to entire MISO footprint




Wind Variability: Impacts on the Electric Power Network

- *Integration costs generally 10% or less of wholesale energy value*
- *Benefit from regional sharing of system-balancing responsibilities*
- *Dedicated “backup generation” or storage not required and not recommended -- remainder of generation fleet compensates for variations in wind*
- *Regional sharing requires robust transmission system*
- *Transmission upgrades and expansion required for major wind expansion -- and for any future growth of the nation’s electric power capability*



European Experience

(data for 2005-2006)	Denmark (W)	Spain	Germany	Ireland
Peak Load (MW)	3,700	44,000	78,000	4,800
Minimum Load (MW)	1,200	17,000	38,000	1,800
Wind Capacity (MW)	2,400	10,000	18,000	600
Wind, % Peak Load	65%	23%	23%	12%
Wind, % Minimum Load	200%	59%	50%	33%
Wind, % Total Energy	24%	7%	5.5%	6%
Capacity Goal by 2010 (MW)	3,600	20,000	25,000	1,200




Mitigating Impacts of Wind's Variability and Uncertainty


- *Improve and use wind forecasting tools*
- *Aggregate wind plant output over large regions*
- *Increase balancing area consolidation and sharing of reliability responsibilities*
- *Develop well-functioning real-time, hour-ahead and day-ahead energy and price responsive load markets and expand access to those markets*
- *Add more flexible generation*
- *Develop demand response capability*

Forecasting and Balancing Markets Reduce Impacts

140 Sites on land every 5min



ERCOT Wind Generation – Feb. 26, 2008



Source: ERCOT



What About Energy Storage?

- ◆ Valuable component of a power system, can provide many benefits
- ◆ Greatest value when operated for benefit of entire system, not dedicated to a single resource
- ◆ One of many sources of flexibility available to the system
- ◆ Integration studies do not show need for storage at 20% wind except possibly on small, isolated systems



Capacity, Energy and Carbon Reduction



Capacity: meeting new load growth and serving peak loads on demand

- ❖ Wind's contribution to capacity is generally a small fraction of its plant rating
- ❖ Wind generally cannot be relied on as operating reserves on a day-to-day basis
- ❖ Existing non-wind generation maintains balance between demand and generation
- ❖ Hence wind requires no new generation to provide "backup"



Capacity, Energy and Carbon Reduction





Energy: displacement of fossil fuels

- ❖ Wind is primarily an energy source
- ❖ System can rely on wind to provide a known amount of energy over some period -- say, a week or a month
- ❖ System can't rely on wind to be operating at a prescribed, specific instant
- ❖ **Wind will displace fuel combustion, and thus greenhouse gases and other emissions**
 - Likely primary system planning criterion



Wind Integration State of the Art: IEEE Power & Energy Magazines November-December 2005 and 2007



❖ www.uwig.org